



CITY OF GOLIAD

152 W. END STREET / P.O. BOX 939

GOLIAD, TEXAS 77963

PH: 361-645-3454 ~ FAX: 361-645-8315

EMAIL: GOLIAD@GOLIADTX.NET

The CITY OF GOLIAD water system PWS ID 0880001 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator or whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring periods 07/01/2016-09/30/2016 (Third Quarter)

We are taking the following actions to address this issue:

Third quarter Disinfectant Level Quarterly Operating Report (DLQOR) have been completed and turned into TCEQ. The CITY OF GOLIAD now has a accountability policy in place to ensure that a laps of this monitoring report does not take place again.

If you have questions regarding this matter, you may contact Tony Saenz at 361-645-9038

5-10-2017

LEAD & COPPER RULE MONITORING AND REPORTING VIOLATION

MANDATORY LANGUAGE-TIER III

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

CITY OF GOLIAD has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 1/1/2016-12/31/2016 we did not complete all testing in the approved time period for (Lead & Copper) and therefore cannot be sure of the quality of the drinking water during that time.

The table below lists the contaminants we did not properly test for during the last year, how often we are supposed to sample for Lead & Copper, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples will be taken.

Contaminant	Required sampling frequency	Number of Samples taken	When samples Should have Been taken	When samples Were or will be taken
Lead & Copper	Annual	10	October 2016	May 2017

What is being done?

The City Of Goliad will sample again twice in 2017 to make up for the samples that were not previously collected on time during the 2016 monitoring period. We will take double the amount of samples this year to get a wide range and idea of water quality in our distribution system. In the future the City Of Goliad will work harder to ensure that a laps of any water quality monitoring does not go past its mandatory due date.

For more information,
Please contact Tony Saenz 361-645-9038
P.O. Box 939 Goliad, TX 7796

5-10-17